



Certificate CN20/42163

The management system of

Connexions Technology (Dong Guan) LTD.

No.6, Shenbao Road, Qishi Town, Dong Guan, Guang Dong,
P.R. China

has been assessed and certified as meeting the requirements of

Regulation (EU) 2016/425 Module C2

For the following activities

Manufacture of CTC(logo), CTPL-0020 folded Particle Filtering
Half Mask.


(Note: All products marked CE0598 must have a valid EU type-
examination certificate issued under Module B or a valid EC type-
examination certificate issued under Article 10 of Directive
89/686/EEC.)

This certificate is valid from 29 July 2020
and remains valid subject to satisfactory surveillance audits.
Issue 1, Certified since 29 July 2020

Authorised by

SGS FIMKO OY, Notified Body 0598
Takomitie 8, FI-00380 Helsinki, Finland
t +358 9 696 361 f +358 9 692 5474 www.sgs.com

Page 1 of 1



This document is issued by the Company subject to its General Conditions of Certification Services accessible at www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. The authenticity of this document may be verified at <http://www.sgs.com/en/verified-clients-and-products/certified-client-directory>. Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Connexions Technology(Dong Guan) LTD.

No.6, Shenbao Road, Qishi Town,
DongGuan,
GuangDong,
China.

It is certified that the manufacturer's technical file and the PPE product detailed on page 2 have been assessed and found to be in accordance with

Regulation (EU) 2016/425 Module B, EU type-examination

This certificate is valid from 22 July 2020 until 22 July 2025
1. Certified since 22 July 2020


Authorised by

SGS FIMKO OY, Notified Body 0598

Takomitie 8, FI-00380, Helsinki, Finland
t +358 9 696 361 f +358 9 692 5474 www.sgs.com

Page 1 of 2

FINAS
Finnish Accreditation Service
S003 (EN ISO/IEC 17065)



This document is issued by the Company subject to its General Conditions of Certification Services accessible at www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues established therein. The authenticity of this document may be verified at <http://www.sgs.com/en/certified-clients-and-products/certified-client-directory>. Any unauthorized alteration, forgery or fabrication of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**Connexions Technology(Dong
Guan) LTD.**

Regulation (EU) 2016/425
Module B, EU type-examination

Issue 1

PPE Product

CTC (logo) CTPL-0020 folded half mask, consisting of five layer (polypropylene/ polypropylene/ polypropylene & hot air cotton/polyester & polyethylene/ polypropylene) disposable particle filtering half mask, with nose clip, and nylon/spandex ear band.

It is certified that the manufacturer's technical file and the above mentioned PPE have been assessed and found to meet the applicable Essential Health and Safety Requirements in Annex II of Regulation (EU) 2016/425 Personal Protective Equipment

The following have been applied:

EN 149:2001+A1:2009 (Respiratory protective devices - filtering half masks to protect against particles) device classification: FFP2 NR.

This certificate is issued on the strict condition that appropriate checks on manufactured PPE, as detailed in Article 19 (c) of the Regulation are implemented and maintained while the model is in production

Certification is based on technical file reference:

Face mask/ CTPL-0020, version 2 dated: 2020-07-21.

SGS Reference Number UK/CRS 241352.

This certificate remains the property of SGS Fimko Oy Ltd to whom it must be returned on request.



Fiscal Year 2020

CERTIFICATION OF REGISTRATION

This certifies that:

CONNEXIONS TECHNOLOGY(DONG GUAN)LTD.

No.6, shenbao road, Qishi Town, DongGuan, GuangDong,China DongGuan,
GUANGDONG, 523000, CHINA

has completed the FDA Establishment Registration and Device Listing.

Owner/Operator Number: 10074051

Listing No.	Product Code	Device Name(s)	Premarket Submission Number/Type	Activities
D403004	MSH	Respirator, surgical	Exempt	Manufacturer

Initial Registration Date: May 18, 2020
Expiration Date: December 31, 2020



中国认可
国际互认
检测
TESTING
CNAS L0599

Test Report SL52025246081401TX Date: June 08,2020 Page 1 of 10

CONNEXIONS TECHNOLOGY (DONG GUAN) LTD
NO. 6, SHENBAO ROAD, QISHI TOWN, DONGGUAN CITY, GUANGDONG PROVINCE

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : (A)Face mask

Style No. : CTPL-0020

Composition : (A)Non-woven fabric, melt-blown fabric, hot air cotton

Sample Color : The test sample is white , the actual color is subject to production.

Manufacturer : CONNEXIONS TECHNOLOGY (DONG GUAN) LTD

Country of Destination : Global

Supplier : CONNEXIONS TECHNOLOGY (DONG GUAN) LTD

Test Performed : Selected test(s) as requested by applicant

Sample Receiving Date : Apr 28, 2020

Testing Period : Apr 29, 2020 - Jun 08, 2020

Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the sample(s) tested, for further details, please refer to the following page(s).

Conclusion:

Sample No.	Recommendation Level
(A)	FFP2 NR

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd Testing Center

Sara Guo

Sara Guo (Account Executive)



SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd
Testing Center

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN_Doccheck@sgs.com

3rd Building No.888, Yehen Road, Xuhui District Shanghai, China 200233 1 (86-21) 61402666 1 (86-21) 64956763 www.sgs.com.cn
中国·上海·徐汇区宜山路888号3号楼 邮编: 200233 1 (86-21) 61402666 1 (86-21) 64956763 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

Test Result

Respiratory Protective Devices — Filtering Half Masks to Protect against Particles — Requirements, Testing, Marking
(EN 149:2001+A1:2009)

Clause 7.4 Packaging
(EN 149:2001+A1:2009 Clause 8.2)

Test Requirement	Results	Comment
Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	Comply	Pass

Clause 7.5 Material
(EN 149:2001+A1:2009, Clause 8.2 & 8.3.1 & 8.3.2)

Test Requirement	Results	Comment
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Comply	Pass
After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps.	Comply	
When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	Comply	
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Comply	

Clause 7.6 Cleaning and Disinfecting
(EN 149:2001+A1:2009, Clause 8.4 & 8.5 & 8.11)

Test Requirement	Results	Comment
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2, after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	Not applicable (Not designed to be re-usable)	N.A.

Clause 7.7 Practical Performance
(EN 149:2001+A1:2009, Clause 8.4)

Test Requirement	Results	Comment
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that cannot be determined by the tests described elsewhere in this standard.	No imperfections	Pass



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing / inspection report & certificates, please contact us at telephone: (86-755) 8307 1443, or e-mail: CN_Doccheck@sgs.com

SGS-CTI (Shanghai) Technical Services Co., Ltd. 200233 1 (86-21) 61402666 1 (86-21) 64956763 www.sgs.com.cn
 3'Building No.888, Yehen Road, Xuhui District Shanghai, China 邮编: 200233 1 (86-21) 61402666 1 (86-21) 64956763 e sgs.china@sgs.com
 中国·上海·徐汇区宜山路888号3号楼

Clause 7.8 Finish of Parts
(EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs	Pass

Clause 7.9.1 Total Inward Leakage
(EN 149:2001+A1:2009, Clause 8.5)

Test Requirement	Results	Comment
The total inward leakage consists of three components: face seal leakage, exhalation value leakage(if exhalation value fitted) and filter penetration. For particulate filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than: 25% for FFP1, 11% for FFP2, 5% for FFP3 and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than: 22% for FFP1, 8% for FFP2, 2% for FFP3	Detail refer to Appendix 1	Meet FFP1, Meet FFP2

Appendix 1: Summarization of Test Data

Inward Leakage Test Data

Subject	Sample No.	Condition	Walk(%)	Head Side/side(%)	Head up/down(%)	Talk(%)	Walk(%)	Mean(%)
Zhou	1	A.R.	6.11	5.08	7.73	5.47	6.33	6.14
Luo	2	A.R.	7.84	6.74	7.17	5.90	8.26	7.18
Lu	3	A.R.	6.44	4.86	6.48	6.18	7.10	6.21
Wang	4	A.R.	5.86	5.60	4.78	5.41	4.82	5.29
Bao	5	A.R.	8.29	8.66	7.51	6.82	5.91	7.44
Ding	6	T.C.	5.59	4.76	5.54	4.97	5.85	5.34
Li	7	T.C.	8.25	7.75	6.81	7.63	8.40	7.77
Chen	8	T.C.	5.45	5.05	5.98	5.58	5.35	5.48
Song	9	T.C.	5.60	6.81	5.64	6.70	6.99	6.35
Ye	10	T.C.	8.33	7.88	8.11	6.80	8.22	7.87

Facial Dimension(mm)

Subject	Face length	Face Width	Face Depth	Mouth Width
Chen	125	150	120	58
Lu	115	132	107	48
Zhou	115	135	106	52
Li	125	130	107	46
Luo	125	136	100	43
Zheng	128	140	112	55
Wang	120	147	103	48
Song	120	140	100	50
Bao	130	134	104	50



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or e-mail: CN_Docscheck@sgs.com

SGS-CTI (Shanghai) Technical Services Co., Ltd. 200233 1 (86-21) 61402666 1 (86-21) 64956763 www.sgs.com.cn
3'Building No.888, Yehen Road, Xuhui District Shanghai, China 200233 中国·上海·徐汇区宜山路888号3号楼 邮编: 200233 1 (86-21) 61402666 1 (86-21) 64956763 e sgs.china@sgs.com
Testing Center



Test Report		SL52025246081401TX		Date: June 08,2020		Page 4 of 10	
Ding	134	150	110	52			
Liu	120	135	117	50			
Ye	126	137	105	52			

Clause 7.9.2 Penetration of Filter Material
(EN 149:2001+A1:2009, Clause 8.11 & EN 13274-7:2019)

Test Requirement				Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.				Detail refer to Appendix 2	Meet FFP1, Meet FFP2
Classification	Maximum penetration of test aerosol				
	Sodium chloride test 95 l/min	Paraffin oil test 95 l/min			
	%	%			
	max.	max.			
FFP1	20	20			
FFP2	6	6			
FFP3	1	1			

Appendix 2: Summarization of Test Data

Penetration of filter material

Aerosol	Condition	Sample No.	Penetration (%)
Sodium chloride test	As received	1	0.117
		2	0.126
		3	0.119
	Simulated wearing treatment	4	0.145
		5	0.190
		6	0.175
		7	0.412
	Mechanical strength + Temperature conditioned	8	0.317
		9	0.396
10		0.201	
11		0.306	
Paraffin oil test	As received	12	0.287
		13	0.279
		14	0.314
	Simulated wearing treatment	15	0.336
		16	3.674
		17	4.124
	Mechanical strength + Temperature conditioned	18	4.176

Flow conditioning : Single filter: 95.0 L/min



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or e-mail: CN_Doccheck@sgs.com

SGS-CTI (Shanghai) Technical Services Co., Ltd. 200233 1 (86-21) 61402666 1 (86-21) 64956763 www.sgs.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 1 (86-21) 61402666 1 (86-21) 64956763 e sgs.china@sgs.com

Clause 7.10 Compatibility with Skin
(EN 149:2001+A1:2009, Clause 8.4 & 8.5)

Test Requirement	Results	Comment
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	No irritation or any other adverse effect to health	Pass

Clause 7.11 Flammability
(EN 149:2001+A1:2009, Clause 8.6)

Test Requirement	Results	Comment
The material used shall not present a danger for the wearer and shall not be of highly flammable nature When tested, the particle filtering half mask shall not burn or not to continue to burn for more than 5 s after removal from the flame.	Detail refer to Appendix 3	Pass

Appendix 3: Summarization of Test Data

Flammability

Condition	Sample No.	Result
As received	1	NIL
	2	NIL
Temperature conditioned	3	NIL
	4	NIL

Clause 7.12 Carbon Dioxide Content of The Inhalation Air
(EN 149:2001+A1:2009, Clause 8.7)

Test Requirement	Results	Comment
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1.0 % (by volume)	Detail refer to Appendix 4	Pass

Appendix 4: Summarization of Test Data

Carbon Dioxide Content of The Inhalation Air

Condition	Sample No.	Result(%)
As received	1	0.4875
	2	0.4862
	3	0.4869
		Mean value:0.49



Clause 7.13 Head Harness
(EN 149:2001+A1:2009, Clause 8.4 & 8.5)

Test Requirement	Results	Comment
The head harness shall be designed so that the particle filtering half mask can be donned and removed easily.	Comply	Pass
The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device.	Comply	

Clause 7.14 Field of Vision
(EN 149:2001+A1:2009, Clause 8.4)

Test Requirement	Results	Comment
The field of vision is acceptable if determined so in practical performance tests.	Comply	Pass

Clause 7.15 Exhalation Valve(s)
(EN 149:2001+A1:2009, Clause 8.2 & 8.9.1 & 8.3.4 & 8.8)

Test Requirement	Results	Comment
(a) A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.	Not applicable due to No exhalation valve	N.A.
(b) If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9.	Not applicable due to No exhalation valve	
(c) Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 s.	Not applicable due to No exhalation valve	
(d) When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10N applied for 10 s.	Not applicable due to No exhalation valve	



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or e-mail: CN_Doccheck@sgs.com

SGS-CTI (Shanghai) Technical Services Co., Ltd. 200233 1 (86-21) 61402666 1 (86-21) 64956763 www.sgs.com.cn
 3 Building No. 888, Yehen Road, Xuhui District Shanghai, China 200233 1 (86-21) 61402666 1 (86-21) 64956763 e sgs.china@sgs.com
 中国·上海·徐汇区宜山路888号3号楼 邮编: 200233 1 (86-21) 61402666 1 (86-21) 64956763

Clause 7.16 Breathing Resistance
(EN 149:2001+A1:2009, Clause 8.9)

Test Requirement				Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.				Detail refer to Appendix 5	Meet FFP1, Meet FFP2, Meet FFP3
Classification	Maximum permitted resistance (mbar)				
	Inhalation		Exhalation		
	30 l/min	95 l/min	160 l/min		
FFP1	0.6	2.1	3.0		
FFP2	0.7	2.4	3.0		
FFP3	1.0	3.0	3.0		

Appendix 5: Summarization of Test Data

Breathing resistance (mbar)

	Flow rate(l/min)	1					2					3					
		A	B	C	D	E	A	B	C	D	E	A	B	C	D	E	
As received	Inhalation	30	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2
		95	0.8	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.7	0.8	0.9	0.8	0.8
	Exhalation	160	1.5	1.6	1.5	1.6	1.7	1.6	1.6	1.6	1.6	1.5	1.6	1.6	1.6	1.6	1.7
Simulated wearing treatment	Inhalation	30	0.3	0.3	0.2	0.2	0.3	0.3	0.2	0.3	0.3	0.2	0.3	0.2	0.3	0.3	
		95	0.9	0.8	0.8	0.7	0.8	0.8	0.8	0.9	0.8	0.8	0.9	0.7	0.8	0.8	0.9
	Exhalation	160	1.6	1.6	1.4	1.5	1.6	1.5	1.5	1.4	1.6	1.6	1.6	1.6	1.5	1.5	
Temperature conditioned	Inhalation	30	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.3	0.2
		95	0.7	0.7	0.6	0.7	0.7	0.6	0.6	0.7	0.6	0.6	0.6	0.6	0.6	0.7	0.7
	Exhalation	160	1.3	1.3	1.4	1.3	1.4	1.3	1.3	1.3	1.4	1.3	1.3	1.4	1.4	1.3	1.4

A: facing directly ahead; B: facing vertically upwards; C: facing vertically downwards; D: lying on the left side; E: lying on the right side

Clause 7.17 Clogging
(EN 149:2001+A1:2009, Clause 8.9 & 8.10)

Test Requirement	Results	Comment																				
<p>Clause 7.17.2 Breathing resistance Valved particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1: 4 mbar, FFP2: 5 mbar, FFP3: 7 mbar at 95L/min continuous flow The exhalation resistance shall not exceed 3 mbar at 160 L/min continuous flow.</p> <p>Valveless particle filtering half masks: After clogging the inhalation and exhalation resistances shall not exceed: FFP1: 3 mbar, FFP2: 4 mbar, FFP3: 5 mbar at 95L/min continuous flow</p>	Optional for single shift device only	N.A.																				
<p>Clause 7.17.3 Penetration of filter material All types (valved and valveless) of particle filtering half masks claimed to meet the clogging requirement shall also meet the requirements.</p> <table border="1"> <thead> <tr> <th rowspan="2">Classification</th> <th colspan="2">Maximum penetration of test aerosol</th> </tr> <tr> <th>Sodium chloride test 95 l/min</th> <th>Paraffin oil test 95 l/min</th> </tr> </thead> <tbody> <tr> <td></td> <td>%</td> <td>%</td> </tr> <tr> <td></td> <td>max.</td> <td>max.</td> </tr> <tr> <td>FFP1</td> <td>20</td> <td>20</td> </tr> <tr> <td>FFP2</td> <td>6</td> <td>6</td> </tr> <tr> <td>FFP3</td> <td>1</td> <td>1</td> </tr> </tbody> </table>	Classification	Maximum penetration of test aerosol		Sodium chloride test 95 l/min	Paraffin oil test 95 l/min		%	%		max.	max.	FFP1	20	20	FFP2	6	6	FFP3	1	1	Optional for single shift device only	N.A.
Classification		Maximum penetration of test aerosol																				
	Sodium chloride test 95 l/min	Paraffin oil test 95 l/min																				
	%	%																				
	max.	max.																				
FFP1	20	20																				
FFP2	6	6																				
FFP3	1	1																				

Clause 7.18 Demountable Parts
(EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand	No demountable parts	N.A.

Test	Uncertainty
Total inward leakage	3.4%
Penetration of filter material	4.8%
Carbon dioxide content of the inhalation air	3.9%
Breathing resistance (30L/min)	5.9%
Breathing resistance (95L/min)	4.9%
Breathing resistance (160L/min)	4.3%

Sample Photo



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN_DocsCheck@sgs.com

13 Building No.88, Yuan Road, Xujia Dieer Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958783 www.sgs.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958783 e sgs.china@sgs.com



(The test sample is white , the actual color is subject to production.)

End of Report



SGS-SONO Technical Services (China) Co., Ltd.
Testing Center (Shanghai)

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8367 1443, or email: CN_Doccheck@sgs.com
J'Building No.888, Yehen Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64956763 www.sgs.com.cn
中国·上海·徐汇区宜山路888号9号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64956763 e sgs.china@sgs.com